

PM#:	Date:
Location #:	Foreman:
QEW Name:	QP Name:

PPE available and inspected	JSA performed
Hazards mitigated	Infrared testing performed
Reduced water pressure to below 75 psi	De-Energized facility
No exposed energized conductors	No excessive strain placed on any termination from the cable
No exposed energized connectors	Capacitive caps and bails are in place and secure
No exposed energized apparatus within enclosure	All terminations are seated flush on their bushings

Notification Number	Address
Name of Employee	Time and Date
Circuit Number	ID of "hot item" type and phase loc
Type of apparatus	Apparatus operating #
Ambient Temp	Emissivity setting
Background temp setting	Apparatus temp
Reference Temp	Temp differential
Weather Conditions	Temp-differential grade
Load amperes	Date maintenance completed
Photo ID#	Photo ID #
Photo ID#	Photo ID #