Monthly Fire Extinguisher Inspection Checklist

Inspector Name:

Inspection Date:

Inspection Requirements

1. Extinguisher is in designated location.
2. Operating instructions facing outward
3. Pressure gauge is in proper range
4. Nozzle is not cracked or clogged.
5. Access is not blocked by other items
6. Tamper indicators and seals are unbroken
7. No corrosion, leakage or physical damage
8. Extinguisher is full (test by hefting)
9. Annual inspection tag is in place
10. Date and initial inspection tag
11. Dry chemical extinguishers only: loosen the powder by inverting and shaking.

If the extinguisher **fails** any part of the inspection, remove from service and immediately notify the vendor, owner and supervisor of the area.

No. Truck#	Size	Type	Location	Pass	Fail	Failed items/comments

Additional Comments: